



GRAFTON
Massachusetts

COPY

Natalia Alward <alwardn@grafton-ma.gov>

Request for Comments: 155 George Hill Road, Solar Energy Generating Facility (SP2019-7/SPA)

Brian Szczurko <szczurkob@grafton-ma.gov>
To: Natalia Alward <alwardn@grafton-ma.gov>
Cc: Paul Cournoyer <cournoyerp@grafton-ma.gov>

Mon, Jun 3, 2019 at 3:56 PM

Drainage improvements need to be assessed along George Hill Road in this area. There is a roadside swale that carries runoff down toward Leland Street and into stormwater infrastructure. We are unaware of the current condition, pipe diameter, etc. The site is currently heavily wooded and once cleared, the runoff coefficient will increase. There are stormwater facilities proposed on site, however, once constructed, O&M plans are often forgotten until it's too late. The roadway and area homes currently experience quite a bit of flooding due to the large areas of cleared farm land. Steps need to be taken to ensure this is not going to escalate current conditions.

Brian Szczurko
Department of Public Works
Engineering
30 Providence Road
Grafton, MA 01519
508-839-5335 x1124
www.grafton-ma.gov
dpw@grafton-ma.gov

EXHIBIT 10

RECEIVED

JUN - 3 2019

**PLANNING BOARD
GRAFTON, MA**

On Fri, May 31, 2019 at 10:24 AM Natalia Alward <alwardn@grafton-ma.gov> wrote:
[Quoted text hidden]